



R-međel_s 31.2 dB
Summa avvikelse 24.8 dB
i_s 34 dB
Skiljeyta 11.2 m²
Rummets volum 55.0 m³

100	18.5 dB
125	17.7 dB
160	17.9 dB
200	20.9 dB
250	25.8 dB
315	26.2 dB
400	29.3 dB
500	30.5 dB
630	32.9 dB
800	34.5 dB
1k	36.7 dB
1.25k	38.6 dB
1.6k	41.9 dB
2k	42.8 dB
2.5k	43.2 dB
3.15k	41.9 dB

HÖGSKOLAN I LULEÅ Akustikgruppen		Diagram nr	
		Mät. 94-11-24	
	30 CL 50 P	Mät. <i>JW</i>	Rit.

Frekv.	α	Frekv.	α
100 Hz	0,27	1,6 k	0,93
125 "	0,37	2 k	0,91
160 "	0,47	2,5 k	0,92
200 "	0,61	3,15	0,89
250 "	0,76		
315 "	0,82		
400 "	0,84		
500 "	0,92		
630 "	0,91		
800 "	0,94		
1 k	0,91		
1,25 k	0,91		

